

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4076-1514:100 Page 1 of 1

CATEGORY: Smoke & Draft Control For Fire Door

LISTEE: Sealeze - A Unit of Jason Inc., 8000 White Pine Road, Richmond, VA 23237
Contact: *Mack Phalen (800) 787-7325

DESIGN: Model Therm-L-Brush II brush type gasketing consisting of a dense pile of fine proprietary nylon filaments. The brush is supplied on a metal spline, which slides into extruded aluminum mounting strips. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, UL and WHI labels.

APPROVAL: Listed as gasketing material for use with separately listed fire-rated hollow metal and steel-covered doors, steel door frames and passenger elevator doors up to 3 hr. rating. Installation and application are subjected to approval by the authority having jurisdiction.

*Rev. 06-22-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager